



# Attestation of Conformity

No. D6 13 02 81493 006

**Holder of Attestation:** **SHIMGE PUMP INDUSTRY GROUP CO.,LTD.**

Dayangcheng Industrial  
317525 Wenling, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Circular Pumps  
Circulation pump**

**Model(s):** **APS25-4-130, APS25-4-180**

**Parameters:**

Rated voltage:	230Vac
Rated frequency:	50/60Hz
Rated input power:	22W
Protection class:	I
Degree of protection:	IP 42
Rated Head:	1.5 m
Rated Flow:	1.8 m <sup>3</sup> /h
Declared EEI:	Less than 0.17

Implementation Measure EC Regulation  
No 641/2009: 22.07.2009  
Amended By EC Regulation  
622/2012: 11.07.2012  
Stage 2 (01 Aug. 2015)


**Tested according to:** PPP 11093B:2012  
EN 1151-1:2006

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

**Test report no.:** 704011285802-05

**Date,** 2013-02-22

Page 1 of 1

  
( Jianying Lu )

